NON-CONVENTIONAL ENERGY SOURCES (SHRI KALP NATH RAI): (a) Yes– Sir, the plant did not function satisfactorily as per the contract.

(b) Failure of the turnkey contractor M/s Volund to rectify the defects and demostrate its performance as per the contract.

(c) Compensation for the entire expenditure incurred on the project has been claimed from M/s VOLUND.

केन्द्रीय क्षेत्र की विद्युत परियोजनाओं को पूरा किया जाना

3014. **श्री कैलाश नारायण सारंग:**
श्री अजीत जोगी:
कुमारी सुशीला तिरिया:

क्या **विद्युत और गैर-पारंपरिक ऊर्जा स्रोत** मंत्री यह बताने कृपा करेंगे कि:

(क) क्या यह सच है कि केन्द्रीय क्षेत्र के विन्ध्याचल ताप विद्युत संयंत्र की 500 मेगावाट क्षमता को अतिरिक्त इंकाई, कवास गैस आधारित विद्युत परियोजना और गांधार गैस आधारित परियोजना का काम आठवीं योजना अवधि के दौरान पूरा कर लिया जाएगा;

(ख) यदि हां, तो इन परियोजनाओं की अधिष्ठापित क्षमता में से मध्य प्रदेश के लिए कितना विद्युत की आपूर्ति की जायेगी?

विद्युत और गैर-पारंपरिक ऊर्जा स्रोत मंत्रालय के राज्य मंत्री (श्री कल्पनाथ राय): (क) राष्ट्रीय ताप विद्युत निगम की कवास गैस विद्युत परियोजना चरण-1 और गंधार गैस विद्युत परियोजना चरण-1 को 8वीं योजना के दौरान पूरा किए जाने की प्रत्याशा है। विन्ध्याचल सुपर ताप विद्युत परियोजना चरण-2 का निर्माण कार्य 8वीं योजना अवधि के बाद भी जारी रहेगा।

(ख) इस परियोजनाओं से मध्य प्रदेश को विद्युत का आबंटन, केन्द्रीय ताप विद्युत केन्द्रों से विद्युत के आबंटन हेतु केन्द्रीय फार्मूले के अनुसार किया जाएगा।

Erratic Power Supply in Laxmi Nagar, Delhi

3015. SHRI CHATURANAN MISHRA: Will the Minister of POWER AND NON-CONVENTIONAL ENERGY SOURCES be pleased to state:

(a) whether it is a fact that for the last two months there is frequent break-down of electric supply in Laxmi Nagar, J-Ext., N-Block- AP-Block and other adjoining blocks in Delhi;

(b) whether it is also a fact that on two or three occasions breakdown was for more than 30 hours;

(c) if so, what are the details thereof; and

(d) what steps are being taken to improve the power supply and check frequent breakdown?

THE MINISTER OF STATE OF THE MINISTRY OF POWER AND NON-CONVENTIONAL ENERGY SOURCES. (SHRI KALP NATH RAI): (a) to (d) According to DESU, there were 8 breakdowns in the said area during the last two months, out of which the electric supply remained disrupted for about 30 hours on one occasion. This was due to the simultaneous fault in both the undergound 11 KV Cables feeding J-Extension Laxmi Nagar Pole-Mounted sub-station. The steps taken to improve the power supply in the area include provision of an additional 11 KV feeder, augmentation of transformer capacity and extensive maintenance of the system.

Rammam Hydel Project in West Bengal

3016. SHRI RATNA BAHADUR RAI: Will the Minister of POWER AND NON-CONVENTIONAL ENERGY SOURCES be pleased to state:

(a) when the work on the Rammam Hydel Project in West Bengal has been started and by when it is likely to be completed;

(b) what is the total estimated cost thereof, and how much has been spent on it so far; and

(c) what will be the generating capacity of this project?

THE MINISTER OF STATE OF THE MINISTRY OF POWER AND NON-